
Intelligent HVDC Control Strategies for Improving AC Network Stability Using Neural Network Models

Dr. Arya Pratama¹, Ir. Nadia Suryani, M.Eng²

Department of Computer Engineering, Universitas Teknologi Indonesia, Jakarta, Indonesia

Faculty of Computer Science, Institut Teknologi Bandung, Bandung, Indonesia

Published Date: - 25 December 2014, Page No.: - 29-34

KEYWORDS

HVDC control, AC system stability, neural networks, intelligent control, power system dynamics, multi-machine networks, oscillation damping, predictive control, system robustness, power electronics.

ABSTRACT

The stability of modern alternating current (AC) power systems is increasingly challenged by the integration of high-voltage direct current (HVDC) links, distributed generation, and renewable energy sources. Traditional HVDC control schemes, while effective under nominal operating conditions, are often constrained by linearized assumptions and fixed parameters, rendering them inadequate for mitigating complex dynamic disturbances such as sudden load changes, line faults, and generator tripping. This paper presents a comprehensive investigation into intelligent HVDC control strategies that leverage artificial neural network (ANN) models to enhance AC network stability. By employing ANN-based predictive controllers in conjunction with conventional HVDC supplementary controls, the proposed approach enables real-time adaptive modulation of active and reactive power flows, thereby improving voltage profiles, damping electromechanical oscillations, and maintaining system frequency within stringent limits. A detailed multi-machine AC system model is developed, incorporating synchronous generator dynamics, excitation and governor systems, and bipolar HVDC links, allowing high-fidelity simulation of transient and small-signal disturbances. The ANN controller is trained using historical system responses to map complex non-linear interactions to optimal control actions, facilitating robust and adaptive performance across varying scenarios. Simulation results demonstrate substantial improvements in key stability metrics, including a reduction in maximum voltage deviations by over 50%, enhanced rotor angle damping by 35%, and frequency deviation mitigation by 57%, compared to conventional HVDC control strategies. Critical analysis reveals that the hybrid ANN-conventional HVDC framework provides both predictive adaptability and operational reliability, addressing limitations of purely linear controllers while maintaining practical feasibility for real-world deployment. The study also examines theoretical and practical implications, including computational requirements, controller interpretability, and training data dependence, and situates the findings within the broader context of intelligent power system control. The proposed methodology offers a scalable, adaptive, and analytically grounded solution for maintaining AC system stability in increasingly complex and interconnected power networks, providing a foundation for future research on reinforcement learning integration, explainable neural network models, and large-scale smart grid applications.

INTRODUCTION

1.1 Problem Statement

The increasing complexity of contemporary power networks, characterized by extensive HVDC interconnections and renewable energy integration, has elevated the challenge of maintaining AC system stability. Conventional HVDC control strategies, while effective under normal operating conditions, are often inadequate during severe disturbances due to their linear control assumptions and fixed parameter settings (Padiyar, 2004). System oscillations, voltage instability, and frequency deviations can propagate rapidly, potentially leading to cascading failures and widespread blackouts (Kundur, 1994). Addressing these challenges requires the development of adaptive, intelligent control methodologies capable of real-time decision-making under non-linear and stochastic conditions.

1.2 Research Relevance

HVDC links are widely employed for long-distance bulk power transmission, interconnecting asynchronous grids, and enhancing system reliability (Ekstrom & Liss, 1970). Incorporating intelligent control paradigms into HVDC operation presents an opportunity to dynamically modulate power flows and damping characteristics, thereby directly improving the transient and small-signal stability of connected AC networks. The application of neural network models in HVDC controls provides a computational framework for learning complex system behaviors, enabling predictive and adaptive responses to disturbances (Widrow & Smith, 1966).

1.3 Objectives

The primary objectives of this research are:

1. To design neural network-based HVDC control strategies capable of enhancing AC network stability under varying operational conditions.
2. To develop a simulation framework for evaluating the performance of intelligent HVDC controllers in multi-machine systems.
3. To analyze the impact of ANN-enhanced HVDC control on damping electromechanical oscillations,

voltage stability, and frequency regulation.

4. To critically compare the proposed intelligent control strategies with conventional HVDC control methodologies.

1.4 Scope and Significance

This study focuses on multi-machine AC systems integrated with HVDC links and emphasizes the comparative performance of traditional versus ANN-based HVDC controllers. The scope includes system modeling, controller design, simulation of disturbances, and analysis of stability indices. The findings provide actionable insights for power system operators and grid planners, highlighting the feasibility of neural network-enhanced HVDC strategies for future smart grid deployments (Smed & Anderson, 1991; Huang & Krishnaswamy, 2002).

LITERATURE REVIEW

2.1 Conventional HVDC Control and AC System Stability

Ekstrom and Liss (1970) introduced a refined HVDC control system that established foundational principles for modulating power flow and stabilizing AC networks. Padiyar (2004) extended this work by formalizing HVDC transmission system models, highlighting the interplay between converter control, line dynamics, and AC network stability. Supplementary HVDC control methods were further examined by Reddy and Rao (2008), demonstrating improved damping of low-frequency oscillations in multi-machine systems.

While these classical approaches provide stability enhancements, they largely rely on linearized models and fixed control parameters, limiting their effectiveness under rapidly changing load conditions and contingencies. Stagg and El-Abiad (1968) emphasized computational methods in power system analysis, suggesting the potential for adaptive control frameworks that can dynamically respond to system nonlinearities.

2.2 Neural Network Applications in Power System Control

Neural networks offer a robust framework for capturing non-linear system behaviors and adapting to varying operational conditions (Widrow & Smith, 1966). Miller et al. (1991) demonstrated the utility of neural networks in control applications, providing a foundation for their integration into power system control schemes. Neural-network-based controllers can learn from historical system responses, anticipate disturbances, and adjust control actions in real-time, thereby complementing existing HVDC strategies.

VK Sood et al. (1994) evaluated neural-network-based PI current controllers for HVDC transmission, illustrating significant improvements in transient response and current regulation compared to conventional controllers. Huang and Krishnaswamy (2002) highlighted the role of HVDC controls in maintaining system stability, advocating for intelligent methodologies to optimize control performance.

2.3 Research Gaps

Despite progress in neural network-based HVDC controls, the literature reveals several gaps:

1. Limited integration of ANN-based predictive control with existing HVDC frameworks in multi-machine AC networks.
2. Insufficient evaluation of combined voltage, frequency, and oscillation damping performance under high-stress scenarios.
3. A lack of comparative analyses between classical HVDC controls and ANN-enhanced strategies using standardized performance metrics.

This study addresses these gaps by developing an integrated ANN-based HVDC control framework, systematically analyzing its performance across key stability indices, and benchmarking against conventional approaches (Widrow & Smith, 1966).

METHODOLOGY

3.1 System Modeling

A multi-machine AC system integrated with a bipolar HVDC link is considered. Each generator is represented by a detailed synchronous machine model, including excitation systems, governor dynamics, and inherent damping characteristics (Kundur, 1994). The HVDC link is modeled using a two-level voltage-source converter representation, allowing precise control of active and reactive power flows.

The system is subjected to typical disturbances such as sudden load changes, line faults, and generator tripping events. Performance indices include rotor angle deviations, bus voltage profiles, and frequency deviations.

3.2 Neural Network Controller Design

An artificial neural network-based controller is developed to modulate HVDC converter currents and voltages. The ANN architecture comprises:

- Input layer: System state variables including generator rotor angles, bus voltages, and AC line currents.
- Hidden layers: Two fully connected layers with nonlinear activation functions (sigmoid and ReLU) for feature extraction and dynamic mapping.
- Output layer: Control signals for HVDC active and reactive power modulation.

The network is trained using historical simulation data and optimized via backpropagation with mean-squared-error minimization. Supervised learning is employed to map system disturbances to appropriate HVDC control actions (Widrow & Smith, 1966).

3.3 Control Strategy Integration

The ANN controller operates in conjunction with conventional HVDC supplementary controls (Reddy & Rao, 2008). During normal operation, the HVDC

link maintains scheduled power transfer. Upon detection of system disturbances, the ANN controller dynamically adjusts converter currents and voltages to damp oscillations and stabilize the network.

A hybrid control framework ensures stability under multiple contingencies by combining fast neural network-based adjustments with slower, robust conventional controllers. This approach mitigates risks associated with overfitting or unstable ANN outputs in unanticipated scenarios.

3.4 Simulation and Evaluation

The integrated system is simulated using MATLAB/Simulink with Power System Toolbox. Disturbances include three-phase faults, sudden load variations, and HVDC line outages. Comparative metrics include:

- Damping ratio of dominant electromechanical modes
- Maximum bus voltage deviations
- Rotor angle swings
- Frequency nadir and settling time

ANN-enhanced HVDC performance is compared to traditional control schemes to quantify improvements in stability and transient response.

RESULTS

The simulation results demonstrate the effectiveness of the ANN-enhanced HVDC control strategies in improving AC network stability under multiple contingencies.

4.1 Voltage Stability

During a sudden 20% load increase in a key bus, the conventional HVDC controller exhibited voltage dips of up to 0.18 pu, while the ANN-enhanced controller reduced the deviation to 0.08 pu. The neural network’s predictive adjustment of converter currents allowed real-time compensation, preventing

voltage collapse at critical nodes (Huang & Krishnaswamy, 2002). Figure 1 illustrates the comparative voltage profiles at Bus 5 under both control schemes.

4.2 Rotor Angle Oscillations

The multi-machine system’s electromechanical oscillations were assessed using rotor angle deviations. Conventional HVDC control resulted in underdamped oscillations with a settling time of approximately 12 seconds. Incorporation of ANN-based predictive control improved damping ratios by 35%, reducing the settling time to 7.8 seconds. The network successfully suppressed low-frequency oscillatory modes without overshoot, highlighting the ANN controller’s capability to anticipate system behavior and modulate power flows effectively (Sood et al., 1994).

4.3 Frequency Regulation

Frequency deviations following generator tripping were also mitigated. The ANN-enhanced HVDC controller maintained system frequency within ± 0.03 Hz, compared to ± 0.07 Hz with conventional control. The ability to dynamically redistribute active power using HVDC links reduced the load on remaining generators and stabilized the overall system frequency (Padiyar, 2004).

4.4 Comparative Performance Analysis

Metric	Conventional HVDC	ANN-Enhanced HVDC	Improvement
Max voltage deviation (pu)	0.18	0.08	55%
Rotor angle settling time (s)	12	7.8	35%
Frequency deviation (Hz)	± 0.07	± 0.03	57%
Damping ratio of dominant mode	0.12	0.22	83%

These results confirm that integrating ANN controllers with HVDC systems substantially enhances voltage stability, oscillation damping, and

frequency regulation. Importantly, the controller remained robust across all tested contingencies, demonstrating its practical applicability for real-world grid operations (Widrow & Smith, 1966).

DISCUSSION

5.1 Theoretical Implications

The findings validate the theoretical premise that neural networks, due to their non-linear mapping capabilities, can effectively augment HVDC control frameworks. By learning system dynamics and predicting disturbance impacts, the ANN controller extends the operational range of HVDC systems beyond linear control assumptions (Miller et al., 1991).

The improvement in damping ratios indicates that the ANN controller effectively modifies HVDC link dynamics to absorb electromechanical energy oscillations. This aligns with classical HVDC control theory, which emphasizes modulation of converter currents to influence AC system stability (Ekstrom & Liss, 1970). However, the neural network introduces adaptability, allowing the controller to respond in real-time to non-linear disturbances that would otherwise be poorly damped.

5.2 Practical Implications

From a practical perspective, deploying ANN-enhanced HVDC controls can increase power system reliability, particularly in grids with high renewable penetration or long-distance HVDC links. Reduced voltage dips and frequency deviations mitigate risks of load shedding and blackouts, providing operational flexibility to grid operators. Furthermore, the hybrid framework combining conventional and ANN-based controls ensures that safety and stability are maintained even under unmodeled contingencies, a critical consideration for regulatory compliance and operational standards (Reddy & Rao, 2008).

5.3 Trade-offs and Limitations

Despite the improvements, several limitations must be acknowledged:

1. Training data dependency: ANN performance relies on comprehensive and representative training data. Incomplete datasets may result in suboptimal control decisions.
2. Computational demand: Real-time ANN computation requires significant processing resources, potentially limiting applicability in legacy systems with constrained hardware.
3. Controller interpretability: Unlike classical HVDC controls, neural networks function as black-box models, making fault diagnosis and verification more challenging.

Future work could focus on integrating reinforcement learning techniques to reduce dependency on pre-collected data and developing explainable neural network models to improve transparency and operator confidence.

5.4 Comparison with Literature

The performance improvements observed in this study corroborate earlier findings on neural network applications in control systems (Widrow & Smith, 1966; Sood et al., 1994). While prior research primarily focused on single-machine HVDC interactions, this study extends the framework to multi-machine networks with dynamic contingencies. Compared to classical HVDC supplementary controls (Reddy & Rao, 2008), the ANN-enhanced approach demonstrates superior damping, voltage regulation, and frequency control.

CONCLUSION

This research presents a comprehensive framework for enhancing AC network stability using ANN-based HVDC control strategies. Key contributions include:

1. Development of an intelligent HVDC control framework integrating neural networks with conventional supplementary controls for multi-

machine AC networks.

2. Demonstration of performance improvements across voltage stability, rotor angle oscillations, and frequency regulation, validated via detailed simulations.

3. Critical analysis of theoretical and practical implications, highlighting trade-offs, limitations, and future research directions.

The study confirms that intelligent HVDC controllers leveraging ANN models provide robust, adaptive, and predictive capabilities, addressing limitations of conventional control strategies. Future research should explore reinforcement learning integration, scalable deployment across larger grids, and real-time operational validation to further advance intelligent power system control.

REFERENCES

1. A Ekstrom and G Liss. "A refined HVDC control system". IEEE Trans. Power Apparatus and Systems. vol. PAS-89, no. 536, May/June 1970.
2. Garng M Huang and Vikram Krishnaswamy. "HVDC Controls for Power System Stability". IEEE Power Engineering Society. pp 597- 602, 2002.
3. KR Padiyar. "HVDC Power Transmission Systems". New Age International (P) Ltd., 2004.
4. P Kundur. "Power System Stability and Control". McGraw- Hill, Inc., 1994.
5. T Smed, G Anderson, "A New Approach to AC/DC Power Flow", IEEE Trans. on Power Systems, Vol. 6, No. 3, pp 1238- 1244, Aug. 1991.
6. VS Reddy, PVR Rao. "Supplementary HVDC Controls for Multi-machine System Stability Improvement". IEEE (India). vol.89, June 2008.
7. VK Sood, N Kandil, RV Patel and K Khorasani. "Comparative Evaluation of Neural-Network-Based and PI Current Controllers for HVDC Transmission". IEEE Transactions on Power Electronics. Vol. 9, No. 3, May 1994.
8. Stagg and El- Abiad. "Computer Methods in Power System Analysis". International Student Edition. McGraw- Hill, Book Company, 1968.
9. B Widrow and F Smith. "Pattern recognizing control system". in Proc. Computational and Informational Sei. (COINS), Washington, Spartan, 1966.
10. W Miller, R Sutton, and P Werbos. "Neural Networks for Control". Cambridge, MA: MIT Press, 1991.