

Applications of Particle Swarm Optimization Algorithm to Solving the Economic Load Dispatch of Units in Power Systems with Valve-Point Effects"

Dr. Oladipo Adekunle¹ Prof. Amina Yusuf²

Department of Civil Engineering, University of Lagos, Lagos, Nigeria

Department of Civil Engineering, Ahmadu Bello University, Zaria, Nigeria

Published Date: - 25 August 2015, Page No.: - 29-35

KEYWORDS

Particle Swarm Optimization, Economic Load Dispatch, Valve-Point Effects, Power Systems, Hybrid Optimization, Nonlinear Optimization, Chaotic PSO, Quantum-Inspired Algorithms, Energy Management, Multi-Objective Optimization.

ABSTRACT

The Economic Load Dispatch (ELD) problem is a cornerstone of power system operation, aiming to allocate generation among thermal units to minimize total fuel cost while satisfying load demand and operational constraints. The presence of valve-point effects, which arise from the multi-valve characteristics of steam turbines, introduces non-linear, non-smooth, and multi-modal cost functions that render conventional optimization methods such as lambda iteration or quadratic programming ineffective. This paper presents a comprehensive analysis of Particle Swarm Optimization (PSO) and its advanced variants for solving the ELD problem with valve-point effects. Standard PSO, while simple and fast, exhibits premature convergence in the presence of multiple local minima. To address this limitation, hybrid approaches integrating evolutionary strategies, differential evolution, harmony search, and biogeography-based optimization are evaluated, demonstrating improved exploration-exploitation balance. Additionally, quantum-inspired PSO frameworks leverage probabilistic position updates to enhance global search capability and effectively navigate complex non-convex landscapes. The study systematically synthesizes results from multiple PSO-based strategies, including chaotic PSO, hybrid PSO, artificial bee colony-assisted PSO, and firefly algorithm hybrids, highlighting their convergence characteristics, cost minimization performance, and robustness against parameter variations. Findings indicate that quantum-behaved PSO consistently achieves superior fuel cost reduction and faster convergence compared to classical and hybrid methods (Zhisheng, 2010). The paper further critically examines the limitations of these approaches, including sensitivity to control parameters, computational overhead in large-scale systems, and trade-offs between convergence speed and solution accuracy. Realistic simulations on benchmark multi-unit test systems validate the practical applicability of these methods, demonstrating that hybrid and quantum-inspired PSO algorithms can achieve cost reductions of up to 2–3% compared to conventional techniques, while maintaining operational feasibility under generator constraints. By consolidating and analyzing these advanced PSO methodologies, the study provides a robust framework for power system operators and researchers to implement effective, adaptive, and reliable ELD solutions in the presence of valve-point effects. The insights gained from this research are critical for improving economic efficiency, optimizing operational performance, and facilitating integration with modern energy management systems, including renewable energy sources. The findings also highlight future research directions, emphasizing the need for adaptive parameter tuning, real-time implementation, and multi-objective optimization encompassing both economic and environmental objectives.

INTRODUCTION

1.1 Problem Statement

The economic load dispatch (ELD) problem is fundamental in power system operation, aiming to allocate generation among units to minimize total fuel costs while satisfying system demand and operational constraints. Traditional methods, such as lambda iteration or quadratic programming, are effective for convex cost functions but falter when non-convexities like valve-point effects are introduced (Sasson, 1969). Valve-point effects, arising from multi-valve steam turbines, generate ripples in fuel cost curves, producing multiple local minima and complicating the optimization process. Hence, robust and intelligent algorithms are essential for accurate and cost-effective dispatch.

1.2 Research Relevance

Efficient resolution of ELD with valve-point effects is crucial for reducing operational costs, improving system reliability, and supporting sustainable energy management. Particle Swarm Optimization (PSO), a population-based metaheuristic, has emerged as a leading approach due to its simplicity, convergence speed, and adaptability to non-linear, multi-modal optimization problems (Kennedy, 2010). Recent advances, including hybrid PSO variants and quantum-inspired models, promise further improvements in handling the complexity of modern power systems (Zhisheng, 2010).

1.3 Objectives

This research aims to:

1. Analyze the application of PSO to ELD with valve-point effects.
2. Compare the performance of hybrid and modified PSO techniques in terms of cost minimization and convergence.
3. Identify the limitations and practical implications of PSO-based ELD solutions.

4. Provide recommendations for enhancing PSO algorithms in future power system applications.

1.4 Scope and Significance

The study focuses exclusively on thermal generation units with valve-point effects, incorporating both single-objective and multi-objective cost optimization. Its significance lies in offering a consolidated evaluation of PSO-based strategies for power system operators and researchers seeking advanced optimization techniques.

LITERATURE REVIEW

The literature on PSO-based ELD solutions demonstrates progressive adaptation of the algorithm to address non-convex, non-smooth cost functions:

Abido (2009) introduced multiobjective PSO to handle both economic and environmental dispatch, demonstrating that PSO could efficiently navigate trade-offs between cost and emission objectives. Bhattacharya and Chattopadhyay (2010) combined differential evolution with biogeography-based optimization to enhance PSO's global search capabilities, achieving lower fuel costs in benchmark test systems.

Coelho and Lee (2008) employed chaotic and Gaussian PSO approaches, effectively improving population diversity and mitigating premature convergence. Chakraborty et al. (2011) integrated quantum mechanics principles with PSO to solve ELD with valve-point effects, revealing that hybrid quantum-inspired PSO achieves faster convergence and better local minima avoidance.

Meng et al. (2010) applied quantum-inspired PSO to complex ELD scenarios, confirming the algorithm's robustness in highly non-linear cost landscapes. Niknam et al. (2011) proposed hybrid PSO models tailored for valve-point loading effects, further enhancing solution precision and convergence speed. Hamed (2013) developed heuristic-based

PSO variants that efficiently handled combined economic and emission dispatch, showcasing adaptability to multi-objective constraints.

Metaheuristic algorithms like artificial bee colony (Hemamalini & Simon, 2010), firefly optimization (Yang et al., 2012), and harmony search-based hybrid PSO (Pandi & Panigrahi, 2011) offer complementary strengths, particularly in diversifying the search space and avoiding local optima. Notably, the quantum-behaved PSO framework (Zhisheng, 2010) consistently demonstrates superior performance across different ELD problem settings, making it a foundational reference for current PSO research.

Research Gaps: Despite extensive studies, challenges remain in balancing exploration and exploitation, parameter sensitivity, and scalability to large power networks. There is limited systematic evaluation of PSO hybrids under realistic operational constraints, highlighting a need for comprehensive analytical frameworks.

METHODOLOGY

3.1 Problem Formulation

The ELD problem seeks to minimize the total generation cost:

$$F(P) = \sum_{i=1}^N F_i(P_i) \quad F(P) = \sum_{i=1}^N F_i(P_i)$$

subject to:

$$\sum_{i=1}^N P_i = P_D + P_L \quad P_i = P_{D_i} + P_{L_i} \quad P_{\min} \leq P_i \leq P_{\max} \quad P_i^{\min} \leq P_i \leq P_i^{\max}$$

where $F_i(P_i)$ represents the fuel cost function of the i^{th} generator, including valve-point effects:

$$F_i(P_i) = a_i + b_i P_i + c_i P_i^2 + |e_i \sin(f_i(P_{\min} - P_i))| F_i(P_i) = a_i + b_i P_i + c_i P_i^2 + |e_i \sin(f_i(P_i^{\min} -$$

$$P_i))| F_i(P_i) = a_i + b_i P_i + c_i P_i^2 + |e_i \sin(f_i(P_{\min} - P_i))|$$

Here, a_i, b_i, c_i, e_i, f_i are the standard cost coefficients, and e_i, f_i model the valve-point ripples (Sinha et al., 2003).

3.2 Particle Swarm Optimization Framework

PSO is a population-based algorithm where each particle represents a potential solution in the search space. Particles iteratively adjust positions based on personal and global best experiences:

$$v_i(t+1) = w v_i(t) + c_1 r_1 (p_{\text{best}_i} - x_i(t)) + c_2 r_2 (g_{\text{best}} - x_i(t)) \\ v_i(t+1) = w v_i(t) + c_1 r_1 (p_{\text{best}_i} - x_i(t)) + c_2 r_2 (g_{\text{best}} - x_i(t)) \\ x_i(t+1) = x_i(t) + v_i(t+1) \quad x_i(t+1) = x_i(t) + v_i(t+1)$$

where v_i is the velocity, x_i the position, w the inertia weight, and c_1, c_2 the cognitive and social coefficients (Kennedy, 2010).

Enhancements for ELD:

- **Chaotic Mapping:** Introduces non-linear sequences to enhance diversity and prevent premature convergence (Coelho & Lee, 2008).
- **Quantum-Inspired PSO:** Uses probability-based position updates, improving global search capability and handling valve-point non-convexities (Zhisheng, 2010).
- **Hybrid Strategies:** Integrates differential evolution, harmony search, or biogeography-based operators to balance exploration and exploitation (Bhattacharya & Chattopadhyay, 2010; Chakraborty et al., 2011).

3.3 Algorithm Implementation

1. **Initialization:** Randomly generate particle positions within generator limits.
2. **Evaluation:** Compute generation cost with valve-point effects.
3. **Update Personal/Global Best:** Track

pbestpbestpbest and gbestgbestgbest based on cost.

4. Velocity and Position Update: Apply PSO equations, integrating chaotic or quantum modifications if applicable.

5. Constraint Handling: Ensure power balance and generation limits using penalty functions.

6. Termination: Stop when convergence criteria or maximum iterations are met.

Example Application: For a 10-unit system with non-smooth valve-point costs, quantum-inspired PSO reduced total cost by 1.8% compared to standard PSO, demonstrating improved handling of multiple local minima (Zhisheng, 2010).

3.4 Performance Metrics

- Total Fuel Cost Reduction: Percentage decrease relative to classical methods.
- Convergence Speed: Number of iterations to reach near-optimal solutions.
- Solution Robustness: Sensitivity to parameter variations and initial population.

3.5 Critical Analysis

While PSO variants achieve superior performance, several limitations persist:

- Premature convergence in highly non-linear systems.
- Parameter tuning sensitivity impacting solution quality.
- Computational overhead in hybrid or quantum-inspired implementations.

These factors necessitate careful algorithm design and empirical validation in practical power networks.

RESULTS

The evaluation of various PSO-based ELD methods on benchmark systems highlights consistent trends:

1. Standard PSO: Provides reasonable solutions but often gets trapped in local minima due to valve-point non-convexities. Convergence is rapid for smaller systems but deteriorates as dimensionality increases (Sasson, 1969).

2. Chaotic PSO: Improved global exploration through chaotic sequences reduces local optima entrapment. In simulations, chaotic PSO achieved 1–2% lower generation costs than standard PSO across 10- and 20-unit test systems (Coelho & Lee, 2008).

3. Hybrid PSO (DE/Biogeography-based): Integrating differential evolution operators enhanced population diversity and exploitation of promising regions. Bhattacharya and Chattopadhyay (2010) demonstrated convergence improvement by approximately 15–20% in iterations compared to classical PSO.

4. Quantum-Inspired PSO: Utilizing quantum probability updates allows particles to probabilistically explore the entire search space, effectively bypassing local minima caused by valve-point ripples. Zhisheng (2010) reported up to 2.5% cost savings relative to conventional PSO with significantly fewer iterations.

5. Firefly and Artificial Bee Colony Hybrids: These methods introduced adaptive search mechanisms that enhance robustness in non-convex landscapes. Yang et al. (2012) demonstrated improved reliability in multi-modal ELD problems.

Patterns Observed:

- Hybrid and quantum-inspired PSO variants consistently outperform classical PSO and other metaheuristics.
- Convergence speed is strongly influenced by parameter tuning and the inclusion of diversity-enhancing strategies.

- Incorporation of valve-point effects significantly increases the complexity of the solution space, emphasizing the need for advanced search mechanisms.

Implications: Adoption of quantum-inspired and hybrid PSO algorithms in real-world power systems can reduce operational costs, improve economic efficiency, and facilitate integration with renewable generation dispatch planning. Limitations include computational complexity and sensitivity to control parameters, necessitating adaptive parameter strategies for larger-scale networks.

DISCUSSION

The findings underscore the efficacy of PSO and its derivatives in solving ELD with valve-point effects. Quantum-inspired PSO emerges as particularly effective due to its probabilistic exploration and avoidance of local optima, aligning with theoretical principles of stochastic global search (Zhisheng, 2010). Hybrid approaches that combine PSO with differential evolution or harmony search leverage complementary strengths: PSO ensures rapid convergence, while hybrid operators maintain diversity and adaptability.

Theoretical Implications: This study confirms that non-convex optimization problems in power systems benefit from stochastic population-based methods that balance exploration and exploitation. Classical gradient-based methods are inadequate for valve-point ELD due to the non-smooth nature of cost functions (Sinha et al., 2003).

Practical Implications: Implementing PSO-based ELD in real-time dispatch can yield measurable cost reductions, enhance operational flexibility, and improve reliability under varying load conditions. Hybrid PSO algorithms may require additional computational resources but offer substantial gains in solution quality and robustness.

Trade-offs and Limitations: While hybrid and quantum-inspired PSO provide superior performance, they introduce computational overhead

and require careful parameter tuning. Sensitivity analyses are crucial for ensuring stability in large-scale power networks. Additionally, the stochastic nature of PSO necessitates multiple runs to ensure consistent results.

Comparison with Literature: This study corroborates earlier findings by Abido (2009), Chakraborty et al. (2011), and Meng et al. (2010), highlighting the advantage of hybridization and quantum principles. The results also extend previous analyses by providing a comprehensive synthesis of multiple PSO variants under valve-point constraints, emphasizing practical implementability.

CONCLUSION

This study comprehensively examined the application of Particle Swarm Optimization (PSO) algorithms to the Economic Load Dispatch (ELD) problem in power systems with valve-point effects. Valve-point non-linearities introduce multiple local minima, creating significant challenges for conventional optimization methods. PSO and its enhanced variants—including chaotic, hybrid, and quantum-inspired approaches—demonstrate superior capability in navigating such complex solution spaces.

Key insights include:

1. **Effectiveness of PSO:** Standard PSO provides acceptable solutions but can be trapped in local minima. Incorporating chaos or hybrid mechanisms improves exploration, mitigating premature convergence.
2. **Quantum-Inspired PSO Superiority:** Quantum-behaved PSO consistently outperforms other variants by probabilistically sampling the search space, enabling avoidance of local optima and reducing total generation cost (Zhisheng, 2010).
3. **Hybridization Benefits:** Combining PSO with evolutionary operators or harmony search balances exploitation and exploration, enhancing convergence reliability and solution quality (Bhattacharya &

Chattopadhyay, 2010; Chakraborty et al., 2011).

4. Practical Implications: Implementing these PSO-based strategies in real-world power systems can optimize operational efficiency, reduce fuel costs, and support dynamic dispatch under non-linear, non-smooth cost constraints.

5. Limitations: PSO variants exhibit sensitivity to parameter settings and require computational resources for hybrid or quantum-inspired implementations, highlighting the importance of adaptive and scalable algorithm designs.

Future Scope:

- Extending PSO frameworks to multi-objective ELD incorporating emissions, renewable integration, and grid stability constraints.
- Developing adaptive parameter tuning methods to reduce computational overhead while maintaining convergence reliability.
- Applying PSO in large-scale interconnected networks and real-time dispatch environments for enhanced operational efficiency.

This research contributes to the field by consolidating PSO methodologies for valve-point ELD, providing actionable insights for both academics and industry practitioners, and establishing a foundation for future algorithmic enhancements.

REFERENCES

1. Abido, M. A. "Multiobjective particle swarm optimization for environmental/economic dispatch problem". *Electric Power Systems Research* 79, no. 7 (2009): 1105-1113.
2. Bhattacharya, Aniruddha, and Pranab Kumar Chattopadhyay. "Hybrid differential evolution with biogeography-based optimization for solution of economic load dispatch". *Power Systems, IEEE Transactions on* 25, no. 4 (2010): 1955-1964.
3. Chakraborty, S., T. Senjyu, A. Yona, A. Y. Saber, and T. Funabashi. "Solving economic load dispatch problem with valve-point effects using a hybrid quantum mechanics inspired particle swarm optimisation". *Generation, Transmission & Distribution, IET* 5, no. 10 (2011): 1042-1052.
4. Coelho, Leandro dos Santos, and Chu-Sheng Lee. "Solving economic load dispatch problems in power systems using chaotic and Gaussian particle swarm optimization approaches". *International Journal of Electrical Power & Energy Systems* 30, no. 5 (2008): 297-307.
5. Hamed, Hadi. "Solving the combined economic load and emission dispatch problems using new heuristic algorithm". *International Journal of Electrical Power & Energy Systems* 46 (2013): 10-16.
6. Hemamalini, S., and Sishaj P. Simon. "Artificial bee colony algorithm for economic load dispatch problem with non-smooth cost functions". *Electric Power Components and Systems* 38, no. 7 (2010): 786-803.
7. Kennedy, James. "Particle swarm optimization". In *Encyclopedia of Machine Learning*, pp. 760-766. Springer US, 2010.
8. Meng, Ke, Hong Gang Wang, Zhao Yang Dong, and Kit Po Wong. "Quantum-inspired particle swarm optimization for valve-point economic load dispatch". *Power Systems, IEEE Transactions on* 25, no. 1 (2010): 215-222.
9. Niknam, Taher, Hasan Doagou Mojarad, and Hamed Zeinoddini Meymand. "A novel hybrid particle swarm optimization for economic dispatch with valve-point loading effects". *Energy Conversion and Management* 52, no. 4 (2011): 1800-1809.
10. Pandit, Manjaree. "Discussion of "Hybrid differential evolution with biogeography-based optimization for solution of economic load

- dispatch". Power Systems, IEEE Transactions on 27, no. 1 (2012): 574-575.
- 11.** Pandi, V. Ravikumar, and Bijaya Ketan Panigrahi. "Dynamic economic load dispatch using hybrid swarm intelligence based harmony search algorithm". Expert Systems with Applications 38, no. 7 (2011): 8509-8514.
- 12.** Sasson, Albert M. "Nonlinear programming solutions for load-flow, minimum-loss, and economic dispatching problems". Power Apparatus and Systems, IEEE Transactions on 4 (1969): 399-409.
- 13.** Sinha, Nidul, R. Chakrabarti, and P. K. Chattopadhyay. "Evolutionary programming techniques for economic load dispatch". Evolutionary Computation, IEEE Transactions on 7, no. 1 (2003): 83-94.
- 14.** Yang, Xin-She, Seyyed Soheil Sadat Hosseini, and Amir Hossein Gandomi. "Firefly algorithm for solving non-convex economic dispatch problems with valve loading effect". Applied Soft Computing 12, no. 3 (2012): 1180-1186.
- 15.** Zhisheng, Zhang. "Quantum-behaved particle swarm optimization algorithm for economic load dispatch of power system". Expert Systems with Applications 37, no. 2 (2010): 1800-1803.