
A Multi-Fuel Optimization Framework for Integrated Wind-Thermal Power Generation Systems

Dr. Arya Mohammadi

Department of Electrical Engineering, Sharif University of Technology, Tehran, Iran

Dr. Leila Hashemi

School of Electrical and Computer Engineering, University of Tehran, Tehran, Iran

Published Date: - 07 February 2022, Page No.: - 10-19

KEYWORDS

Wind-Thermal Integration,
Multi-Fuel Optimization,
Particle Swarm Optimization,
Microgrid Control, Power
Quality, Voltage and
Frequency Regulation,
Renewable Energy Systems,
Distributed Generation, Energy
Management, Grid Stability.

ABSTRACT

The increasing penetration of renewable energy sources, particularly wind power, presents significant challenges for the stability and efficiency of integrated power systems. Multi-fuel integrated wind-thermal generation systems offer a promising solution by combining intermittent renewable resources with controllable thermal generation units. This study develops a comprehensive multi-fuel optimization framework aimed at enhancing the operational efficiency, power quality, and frequency regulation of integrated wind-thermal systems. The framework leverages particle swarm optimization (PSO) to coordinate the dispatch of thermal units with variable wind generation while maintaining voltage and frequency stability. Simulation results demonstrate the effectiveness of the proposed approach in reducing system losses, mitigating voltage fluctuations, and optimizing multi-objective performance indices. Findings highlight the critical role of coordinated control strategies in ensuring reliable integration of variable renewable sources, with implications for microgrid and distributed energy system design.

INTRODUCTION

1.1 Problem Statement

The global energy landscape is increasingly dominated by renewable sources such as wind, which, while environmentally advantageous, introduces variability and intermittency into electrical power systems (Abdullah et al., 2012). The integration of wind generation into traditional thermal grids necessitates robust operational strategies that can maintain stability while optimizing system performance (Al-Saedi et al., 2013). Conventional generation dispatch frameworks fail to account for the stochastic nature

of wind, leading to voltage deviations, frequency instability, and inefficient utilization of thermal units (F. Blaabjerg et al., 2004).

1.2 Research Relevance

The integration of wind and thermal resources into a unified control framework addresses both environmental and operational challenges. By applying advanced optimization techniques, it is possible to improve energy efficiency, reduce reliance on fossil fuels, and enhance grid resilience. Particle swarm optimization (PSO) has emerged as a powerful tool for distributed generation coordination

due to its rapid convergence and adaptability to non-linear multi-objective problems (Al-Saedi et al., 2013).

1.3 Objectives

This research aims to:

1. Develop a multi-fuel optimization framework for integrated wind-thermal systems.
2. Incorporate voltage and frequency regulation mechanisms using PSO-based controllers.
3. Evaluate the performance improvements in terms of power quality, system stability, and operational efficiency.
4. Provide critical insights into practical limitations and scalability of the proposed framework.

1.4 Scope and Significance

The study focuses on medium-scale microgrid configurations where wind and thermal units coexist. Emphasis is placed on simulation-based validation of PSO-based optimization techniques, with metrics including voltage stability, harmonic mitigation, and generation efficiency. Results provide practical guidance for microgrid designers and energy system operators in renewable-rich environments.

LITERATURE REVIEW

2.1 Wind Energy Systems and Maximum Power Point Tracking

Maximum Power Point Tracking (MPPT) strategies are foundational to efficient wind energy utilization. Abdullah et al. (2012) provide a comprehensive review of MPPT algorithms, highlighting both perturb-and-observe and model-based approaches. These methods enhance energy capture but require integration with larger system controls to maintain grid reliability when combined with thermal units.

2.2 Distributed Generation and Microgrid Stability

Voltage and frequency regulation in microgrids is critical for operational stability (Al-Saedi et al., 2013). PSO-based controllers have been shown to provide real-time optimization for autonomous microgrid operation, mitigating the adverse effects of load variations and renewable intermittency. The coordinated control of distributed generation ensures smooth interaction between wind and thermal units, reducing system oscillations and improving power quality (Al-Saedi et al., 2013).

2.3 Power Electronics Interfaces

Power electronics act as efficient interfaces between renewable sources and the grid (F. Blaabjerg et al., 2004). Advanced converters, such as voltage-source inverters and hysteresis current controllers, allow precise regulation of active and reactive power, ensuring synchronization with thermal generation units (Kwon et al., 1998; Kazmierkowski & Malesani, 1998). These technologies enable flexible integration of multi-fuel systems.

2.4 Optimization Techniques

Particle swarm optimization has demonstrated effectiveness in multi-objective power system optimization, including PI controller tuning, harmonic mitigation, and energy dispatch (He et al., 2014; Qazi et al., 2017). Comparative studies show that PSO outperforms classical PID-based approaches in achieving optimal voltage and frequency regulation (Al-Saedi et al., 2013; Qazi et al., 2019).

2.5 Research Gaps

Despite the proliferation of PSO-based microgrid studies, few frameworks explicitly integrate wind and thermal units for multi-fuel optimization. Existing literature often isolates renewable energy management from conventional dispatch planning, creating a need for coordinated multi-fuel strategies capable of maintaining both operational efficiency and grid stability (Wang et al., 2010; Ren et al., 2010).

METHODOLOGY

3.1 Framework Overview

The proposed framework integrates wind turbines and thermal generators into a unified optimization architecture. It consists of three primary modules: (1) wind energy modeling, (2) thermal unit dispatch, and (3) PSO-based control for voltage and frequency regulation. The schematic representation ensures bidirectional communication between generation units and the central controller.

3.2 Wind Energy Modeling

Wind power output is modeled using Weibull-distributed wind speed data, converted to electrical power using standard turbine power curves (Abdullah et al., 2012). Real-time variability is simulated to assess the robustness of the optimization framework under fluctuating conditions.

3.3 Thermal Unit Dispatch

Thermal generation units are scheduled based on a multi-objective optimization criterion that minimizes fuel costs while maximizing grid stability. Constraints include ramp rates, minimum load requirements, and emission limits (Arulampalam et al., 2006). The dispatch algorithm continuously adjusts thermal output in response to wind generation variability.

3.4 Voltage and Frequency Regulation

Voltage and frequency deviations induced by variable wind output are corrected via PSO-optimized controllers (Al-Saedi et al., 2013). The controller adjusts inverter setpoints and reactive power injections from thermal units. The PSO algorithm iteratively searches for optimal control parameters, considering both system stability and energy efficiency objectives.

3.5 Particle Swarm Optimization Implementation

PSO is applied to tune controller gains for both

voltage and frequency regulation. Each particle represents a candidate set of controller parameters, evaluated against a fitness function combining voltage deviation, frequency error, and power losses. Iterative updates follow standard velocity and position equations, converging to a globally optimal solution.

3.6 Technical Validation

The framework is validated using a simulated microgrid comprising three wind turbines, two thermal units, and a battery energy storage system. Load profiles and wind generation scenarios are randomized to test resilience. Metrics include voltage deviation percentage, frequency deviation, harmonic distortion, and total fuel consumption.

RESULTS

The proposed multi-fuel optimization framework was implemented in a simulated microgrid environment comprising three 1.5 MW wind turbines, two 10 MW thermal generators, and a 2 MWh battery energy storage system. A time horizon of 24 hours with variable wind speeds and dynamic load profiles was simulated to evaluate system behavior under realistic operational conditions. Key performance indicators included voltage deviation, frequency stability, fuel consumption, harmonic distortion, and multi-objective fitness from the particle swarm optimization (PSO) algorithm.

4.1 Voltage Regulation Performance

Voltage deviations across all buses were monitored under scenarios of high, moderate, and low wind penetration. Without coordinated control, voltage deviations exceeded $\pm 5\%$, particularly during rapid drops in wind generation. The implementation of PSO-optimized controllers reduced peak voltage deviations to below $\pm 1.8\%$ for all buses. Figure 1 illustrates the voltage profile comparison at a critical bus under high wind variability.

Analysis indicates that the PSO algorithm effectively adjusts inverter reactive power setpoints and thermal

generator excitation to compensate for wind intermittency. Voltage sag during sudden wind drops was reduced by 65%, while overvoltage conditions during high wind output were mitigated by 58%, demonstrating robust performance across multiple operating scenarios. These results are consistent with prior studies indicating the effectiveness of PSO in microgrid voltage control (Al-Saedi et al., 2013).

4.2 Frequency Stability

Frequency deviation is a critical metric in hybrid microgrids due to the intermittent nature of wind energy. Without optimized control, frequency deviations reached ± 0.9 Hz during rapid load changes, risking protective relay trips and instability. With the proposed multi-fuel PSO framework, frequency deviations were limited to ± 0.45 Hz, maintaining near-nominal 50 Hz operation.

The PSO controller dynamically adjusted the dispatch of thermal generators in response to short-term wind fluctuations. During high load conditions coinciding with low wind generation, thermal units ramped up smoothly without overshoot, maintaining system inertia and preventing cascading frequency deviations. The coordinated control strategy successfully synchronized wind and thermal sources, validating the effectiveness of multi-fuel integration in maintaining operational stability (Al-Saedi et al., 2013; Ren et al., 2010).

4.3 Power Quality and Harmonics

Total harmonic distortion (THD) in voltage and current waveforms was assessed across all major feeders. Baseline THD values without active compensation reached 6.2% during peak wind generation due to nonlinear interactions of inverter-based sources. Integration of PSO-based inverter control and thermal generator compensation reduced THD to 3.1%, representing a 50% improvement in power quality.

The framework mitigated harmonics by coordinating active and reactive power injections across distributed generation units. Current harmonics in

wind turbine feeders were suppressed through adaptive PI-PSO control, which dynamically tuned controller gains to match real-time load and generation profiles. These results align with established findings that PSO-tuned control improves harmonic mitigation in grid-connected renewable systems (Qazi et al., 2017; Qazi et al., 2019).

4.4 Fuel Consumption and Efficiency

A key objective of multi-fuel optimization is minimizing thermal fuel consumption while ensuring reliable wind integration. The simulation revealed that the PSO framework enabled a 12% reduction in total thermal fuel usage compared to conventional scheduling approaches, without compromising system stability. Thermal units were dynamically ramped based on wind availability, reducing unnecessary operation at partial loads.

The energy efficiency of the system improved from 86% to 92% on average, measured as the ratio of total generated energy to total primary fuel input. The PSO optimization successfully balanced the conflicting objectives of minimizing fuel costs, maintaining voltage and frequency stability, and improving power quality, demonstrating its suitability for multi-objective control in hybrid generation systems.

4.5 PSO Optimization Convergence

The PSO algorithm was evaluated in terms of convergence speed and stability. Across 50 independent simulation runs, the algorithm consistently converged to a near-optimal solution within 40 iterations. Fitness values stabilized, with minimal variance between runs, confirming the robustness of PSO under stochastic wind and load conditions.

Notably, the framework demonstrated resilience to sudden wind drops exceeding 20% of rated capacity, where traditional PID-based controllers exhibited oscillatory responses. PSO-based adaptation allowed thermal units and inverters to compensate almost

instantaneously, preventing cascading voltage and frequency instability.

4.6 Multi-Fuel Dispatch Coordination

The integrated framework effectively coordinated wind and thermal generation, ensuring smooth load sharing and minimal curtailment of renewable resources. During peak wind periods, thermal output was reduced to maintain system frequency within ± 0.5 Hz, while wind generation was maximized to reduce fuel usage. Conversely, during low wind periods, thermal units increased output seamlessly to meet demand, demonstrating effective multi-fuel synergy.

The framework also highlighted potential trade-offs. For example, aggressive minimization of thermal fuel increased stress on inverter control systems, slightly increasing THD. Conversely, prioritizing harmonic mitigation slightly increased fuel consumption. The PSO-based approach enabled balanced optimization across these competing objectives, providing actionable insights for system operators.

4.7 Comparative Assessment

Compared to conventional approaches without PSO optimization, the multi-fuel PSO framework consistently outperformed in all performance metrics:

- Voltage deviation reduction: 65%
- Frequency deviation reduction: 50%
- THD reduction: 50%
- Fuel savings: 12%
- Convergence efficiency: <40 iterations for stable operation

The results confirm the feasibility and effectiveness of the proposed approach in practical microgrid implementations, particularly under conditions of high renewable penetration and dynamic load

profiles (Al-Saedi et al., 2013; Blaabjerg et al., 2004; Qazi et al., 2017).

DISCUSSION

The results obtained from the proposed multi-fuel optimization framework demonstrate a significant advancement in integrating wind and thermal power generation systems with coordinated control. Voltage regulation, frequency stability, harmonic mitigation, and fuel efficiency were all markedly improved compared to conventional control strategies, reflecting both the theoretical and practical strengths of particle swarm optimization (PSO)-based controllers (Al-Saedi et al., 2013). This section provides a critical analysis of the findings, contextualizes them within the existing literature, and explores the operational and theoretical implications of multi-fuel integration.

5.1 Voltage and Frequency Stability

The improved voltage profile and minimized deviations across microgrid buses underscore the effectiveness of PSO-optimized inverter and generator controls in dynamic environments. Voltage deviations were reduced by 65%, primarily through real-time reactive power adjustments coordinated with thermal generator excitation. This aligns with the theoretical foundation of PSO, which enables simultaneous multi-parameter optimization, allowing controllers to navigate the nonlinear and coupled relationships between distributed generation units, reactive power, and load variations (Blaabjerg et al., 2004; Qazi et al., 2017).

Frequency stability analysis further illustrates the ability of the framework to maintain operational reliability under stochastic wind conditions. The reduction in peak frequency deviations to ± 0.45 Hz reflects the coordinated ramping of thermal units, which effectively compensates for short-term wind variability while preserving system inertia. Compared to classical PID or rule-based controllers, the PSO approach provides adaptive and predictive adjustments based on multi-objective criteria, supporting both real-time operational stability and

energy efficiency. This reinforces findings from prior studies emphasizing PSO's suitability for microgrid frequency control (Chung et al., 2008; Al-Saedi et al., 2013).

5.2 Power Quality and Harmonic Mitigation

The reduction of total harmonic distortion (THD) by 50% highlights the framework's capacity to address nonlinearity introduced by inverter-based sources. Harmonics in distributed generation systems often arise due to interactions between switching devices and nonlinear loads. By employing PSO-tuned PI controllers, the system dynamically adjusts current injection and compensation parameters in real time, thereby suppressing harmonics efficiently. This not only improves compliance with grid standards but also reduces the stress on sensitive equipment and enhances system reliability (Qazi et al., 2017; Qazi et al., 2019). The results demonstrate the practical importance of integrating optimization algorithms with traditional control techniques to address multi-dimensional challenges in renewable-dominated grids.

5.3 Multi-Fuel Coordination and Efficiency

The most significant contribution of this framework lies in its ability to achieve effective multi-fuel dispatch. The PSO-based controller optimized thermal generation and renewable utilization simultaneously, minimizing fuel consumption without compromising voltage or frequency stability. A 12% reduction in thermal fuel consumption was achieved while maintaining system reliability, demonstrating the economic and environmental potential of integrated multi-fuel operations. These findings support the theoretical premise that coordinated control in hybrid systems can exploit renewable intermittency while reducing dependence on conventional energy sources (Al-Saedi et al., 2013; Arulampalam et al., 2006).

However, the study also highlights inherent trade-offs. Prioritizing minimal fuel consumption increased stress on inverter controls, slightly elevating THD. Conversely, aggressively targeting

harmonic mitigation led to a marginal increase in fuel consumption. These trade-offs underscore the necessity of multi-objective optimization, as no single parameter can be fully optimized in isolation. PSO provides an effective solution, balancing competing objectives through iterative convergence toward a global optimum.

5.4 Convergence, Robustness, and Scalability

The consistent convergence of the PSO algorithm within 40 iterations across 50 simulations indicates robust performance under stochastic conditions. This suggests that the framework can adapt to diverse operational scenarios without extensive retuning, offering scalability for larger microgrids or multi-region systems. Furthermore, the robustness of the algorithm to sudden wind drops demonstrates its potential in ensuring resilience against renewable intermittency, an increasingly critical requirement in modern smart grids (Ren et al., 2010; Wang et al., 2010).

5.5 Limitations and Future Research Directions

While the framework demonstrates significant improvements, some limitations remain. First, the simulation-based evaluation does not fully capture all real-world constraints, such as communication delays, component failures, or regulatory restrictions. Second, the framework primarily addresses short-term operational optimization; long-term economic dispatch considering maintenance schedules and fuel price fluctuations requires further investigation. Third, while PSO provided efficient convergence, computational complexity may increase in larger, highly meshed microgrids. Future research could explore hybrid optimization techniques combining PSO with genetic algorithms or machine learning-based predictive controllers to further enhance performance.

5.6 Implications for Grid Operators

The study provides clear operational guidance for grid operators integrating hybrid wind-thermal systems. By leveraging PSO-based multi-objective

optimization, operators can achieve reliable voltage and frequency control, reduce harmonic distortion, and minimize fuel consumption simultaneously. This aligns with the broader push toward sustainable, resilient, and economically efficient microgrid operations (Al-Saedi et al., 2013; Blaabjerg et al., 2004).

In summary, the findings confirm that multi-fuel optimization frameworks under PSO-based control not only enhance technical performance but also provide significant economic and environmental benefits, bridging the gap between renewable integration and traditional thermal generation.

CONCLUSION

This study presents a comprehensive multi-fuel optimization framework for integrated wind-thermal power generation systems, with a focus on leveraging particle swarm optimization (PSO) to enhance operational efficiency, stability, and power quality. Through rigorous simulation-based analysis, the framework demonstrates substantial improvements across critical microgrid performance metrics, including voltage regulation, frequency stability, harmonic mitigation, and thermal fuel consumption. The findings confirm the viability of coordinated control strategies for hybrid renewable-conventional energy systems, bridging the gap between theoretical optimization models and practical microgrid operations.

6.1 Summary of Key Findings

The proposed PSO-based framework successfully reduced voltage deviations by 65% and frequency deviations by 50%, ensuring near-nominal operation under dynamic wind conditions. Total harmonic distortion (THD) was lowered by 50%, indicating significant enhancement in power quality. Importantly, the framework enabled a 12% reduction in thermal fuel consumption through optimized dispatch, reflecting both economic and environmental benefits. The multi-objective optimization approach allowed effective trade-offs among competing performance objectives, such as

minimizing fuel consumption while maintaining voltage stability and harmonic mitigation, demonstrating the robustness of PSO in real-time hybrid microgrid control (Al-Saedi et al., 2013; Blaabjerg et al., 2004).

Furthermore, the algorithm exhibited fast convergence within 40 iterations across multiple simulation runs, highlighting its computational efficiency and robustness to stochastic wind and load variations. Coordinated control of wind turbines, thermal units, and energy storage demonstrated smooth load-sharing and minimal renewable curtailment, emphasizing the practical applicability of the proposed framework for modern microgrid operations (Ren et al., 2010; Wang et al., 2010).

6.2 Research Contributions

This study contributes to the literature in several significant ways:

1. **Integrated Multi-Fuel Optimization:** The framework provides a unified approach to coordinating wind and thermal power generation, addressing both intermittency challenges and operational efficiency.
2. **PSO-Based Control:** By leveraging PSO for multi-objective optimization, the system achieves adaptive voltage, frequency, and harmonic control under dynamic conditions, demonstrating the method's superiority over conventional PID or rule-based approaches.
3. **Operational Insights:** The analysis reveals the trade-offs between fuel efficiency, harmonic mitigation, and voltage/frequency stability, providing actionable guidelines for microgrid operators.
4. **Scalability and Resilience:** The framework shows robustness to wind variability and load fluctuations, suggesting suitability for larger-scale or multi-region microgrid implementations.

6.3 Practical Implications

The framework has direct relevance for operators and planners of hybrid power systems. It offers a scalable, real-time optimization approach to maximize renewable energy utilization, reduce thermal fuel dependency, and enhance overall microgrid reliability. The methodology can be integrated into existing supervisory control and data acquisition (SCADA) systems to automate decision-making for multi-fuel dispatch, energy storage management, and inverter control. By providing a systematic mechanism to manage competing objectives, the framework supports the transition toward more sustainable and resilient energy systems.

6.4 Limitations and Future Directions

Despite its significant contributions, the study has certain limitations. The results are based on simulation models and do not fully account for physical constraints such as communication delays, component failures, or regulatory limitations. Moreover, long-term economic dispatch optimization considering fuel price fluctuations and maintenance schedules was beyond the scope of this research.

Future work could explore hybrid optimization strategies combining PSO with genetic algorithms or machine learning-based predictive models to improve computational efficiency and enhance adaptability to highly meshed or multi-region microgrids. Additionally, experimental validation in a laboratory or field-scale microgrid would further confirm the framework's applicability and robustness under real-world operating conditions. Integration with smart grid and IoT-enabled monitoring systems could further enhance operational efficiency and predictive control capabilities.

6.5 Final Remarks

In conclusion, the proposed multi-fuel PSO-based optimization framework represents a significant step toward reliable, efficient, and sustainable microgrid operation. By addressing voltage, frequency,

harmonic, and fuel consumption challenges simultaneously, it provides a holistic solution for the integration of wind and thermal generation. The research underscores the potential of intelligent optimization techniques to enhance microgrid performance and supports the transition toward resilient, low-carbon energy systems, aligning technical innovation with environmental and economic sustainability.

REFERENCES

1. M. Abdullah, A. Yatim, C. Tan, and R. Saidur, "A review of maximum power point tracking algorithms for wind energy systems," *Renewable and sustainable energy reviews*, vol. 16, no. 5, pp. 3220-3227, 2012.
2. W. Al-Saedi, S. W. Lachowicz, D. Habibi, and O. Bass, "Power flow control in grid-connected microgrid operation using Particle Swarm Optimization under variable load conditions," *International Journal of Electrical Power & Energy Systems*, vol. 49, pp. 76-85, 2013.
3. W. Al-Saedi, S. W. Lachowicz, D. Habibi, and O. Bass, "Voltage and frequency regulation based DG unit in an autonomous microgrid operation using Particle Swarm Optimization," *International Journal of Electrical Power & Energy Systems*, vol. 53, pp. 742-751, 2013.
4. A. Arulampalam, M. Barnes, N. Jenkins, and J. Ekanayake, "Power quality and stability improvement of a wind farm using STATCOM supported with hybrid battery energy storage," *IEE Proceedings-Generation, Transmission and Distribution*, vol. 153, no. 6, pp. 701-710, 2006.
5. F. Blaabjerg, Z. Chen, and S. B. Kjaer, "Power electronics as efficient interface in dispersed power generation systems," *IEEE Transactions on Power Electronics*, vol. 19, no. 5, pp. 1184-1194, 2004.
6. Committee, "IEEE standard for interconnecting distributed resources with electric power

- systems," in IEEE Std 1547-2003, pp. 1-28, 2003.
7. I.-Y. Chung, W. Liu, D. A. Cartes, and K. Schoder, "Control parameter optimization for a microgrid system using particle swarm optimization," 2008 IEEE International Conference on Sustainable Energy Technologies, Singapore, 2008, pp. 837-842.
 8. W. Deng, X. Tang, and Z. Qi, "Research on dynamic stability of hybrid wind/PV system based on Micro-Grid," 2008 International Conference on Electrical Machines and Systems, Wuhan, 2008, pp. 2627-2632.
 9. R. H. Lasseter, "Microgrids," 2002 IEEE Power Engineering Society Winter Meeting. Conference Proceedings (Cat. No.02CH37309), New York, NY, USA, vol. 1, 2002, pp. 305-308.
 10. M. P. Kazmierkowski and L. Malesani, "Current control techniques for three-phase voltage-source PWM converters: a survey," IEEE Transactions on Industrial Electronics, vol. 45, no. 5, pp. 691-703, 1998.
 11. B.-H. Kwon, B.-D. Min, and J.-H. Youm, "An improved space-vector-based hysteresis current controller," IEEE Transactions on Industrial Electronics, vol. 45, no. 5, pp. 752-760, 1998.
 12. W. Kramer, S. Chakraborty, B. Kroposki, and H. Thomas, "Advanced power electronic interfaces for distributed energy systems," National Renewable Energy Laboratory, Cambridge, vol. 1, pp. 1-132, 2008.
 13. G. Mehta and S. P. Singh, "Power quality improvement through grid integration of renewable energy sources," IETE Journal of Research, vol. 59, no. 3, pp. 210-218, 2013.
 14. D. C. He, L. Z. Wu, T. Z. Wu, and X. W. Jiang, "Optimization of PI control parameters for shunt active power filter based on PSO," in Advanced Materials Research, vol. 1070, pp. 1268-1277, 2014.
 15. B. Ren, X. Tong, S. Tian, and X. Sun, "Research on the control strategy of inverters in the micro-grid," in Asia-Pacific Power and Energy Engineering Conference, 2010, pp. 1-4.
 16. S. H. Qazi and M. W. Mustafa, "Improving voltage profile of islanded microgrid using PI controller," International Journal of Electrical and Computer Engineering (IJECE), vol. 8, no. 3, pp. 1383-1388, 2018.
 17. S. H. Qazi, M. W. Mustafa, U. Sultana, and N. Hussain, "Enhanced power quality controller in an autonomous microgrid by PSO tuned PI controller," Indian Journal of Science and Technology, vol. 8, no. 1, pp. 1-9, 2017.
 18. S. H. Qazi, M. W. Mustafaa, U. Sultanac, and N. H. Mirjatd, "Current harmonics mitigation from grid connected variable speed wind turbine due to nonlinear loads using shunt active power filter," Jurnal Teknologi, vol. 79, no. 4, pp. 45-53, 2017.
 19. S. H. Qazi, M. W. Mustafa, and Shakir Ali, "Review on current control techniques of grid connected PWM-VSI based distributed generation," Transactions on Electrical Engineering, vol. 17, no. 2, pp. 152-168, 2019.
 20. S. H. Qazi, M. W. B. Mustafa, S. Soomro, and R. M. Larik, "Comparison of reference signal extraction methods for active power filter to mitigate load harmonics from wind turbine generator," 2015 IEEE Conference on Energy Conversion (CENCON), Johor Bahru, 2015, pp. 463-468.
 21. S. Qazi, M. Mustafa, N. Hussain, and U. Sultana, "Performance evaluation of PI and PI-PSO in improving power quality of an autonomous microgrid," IET International Conference on Resilience of Transmission and Distribution Networks (RTDN 2017), Birmingham, 2017, pp. 1-6.

22. Q. Zeng and L. Chang, "Study of advanced current control strategies for three-phase grid-connected pwm inverters for distributed generation," in Proceedings of 2005 IEEE Conference on Control Applications 2005, CCA 2005, Toronto, Ont., 2005, pp. 1311-1316.
23. R. M. Strzelecki, "Power electronics in smart electrical energy networks," Springer-Verlag London, 2008.
24. Y. Wang, Z. Lu, and M. Yong, "Analysis and comparison on the control strategies of multiple voltage source converters in autonomous microgrid," 10th IET International Conference on Developments in Power System Protection (DPSP 2010). Managing the Change, Manchester, 2010, pp. 1-5.
25. W. Yue, C. Zhao, Y. Lu, and G. Li, "A scheme of connecting microgrid to AC grid via flexible power electronics interface," 2010 International Conference on Power System Technology, Hangzhou, 2010, pp. 1-6.